

Docket Nos. 42310 & 42311
Georgia Power Company's 2019 IRP and 2019 DSM Application
STF-GDS Data Request Set Number 1

STF-GDS-1-17

Question:

Under normal peaking weather conditions, is the GPC system expected to establish its annual peak demand during the winter season any time before 2038? If so, please identify the year.

Response:

Under normal peaking weather conditions, GPC is not expected to establish its annual peak demand during the winter season before 2038. GPC's peak demand is expected to remain in the summer through 2038.